



3933 US Route 11 Cortland, New York 13045 USA Phone Number: (800) 345-3851 Fax Number: (607) 758-6637 Web: www.intertek.com

## ETL Verified Certificate of Conformance Number: 2034144CRT-003

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the electrical transmission requirements of the referenced specification(s) at the time the tests were carried out.

Rendered to:

**Berk-Tek LLC** 

132 White Oak Rd New Holland, PA 17557

www.leviton.com/berktek

Contact: Mr. Michael Boland

**Product tested:** Category 6, 4-pair, 23 AWG, U/UTP, CMP, horizontal (solid) cable

Part number(s): LM-2000 CMP UTP
Compliant to: ANSI/TIA-568.2-E

ISO/IEC 11801-1

LM-2000

Authorized marking: ETL VERIFIED TO ANSI/TIA-568.2-E, ISO/IEC 11801-1 and LM-2000 CATEGORY 6

Continuing compliance to this specification is monitored through production testing, ongoing inspections by Intertek at the production facility and random sample testing.

Date Issued: 24-Jan-2001 Date Revised: 27-Nov-2024

Approved By: / MOIVE | elsother

Antoine Pelletier, Project Engineer

This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification notice.

NOTE: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.