



PUBLIC NOTICE


Intertek Warns of Falsified Intertek Test Report: Innovative Metal Industries In-Line Silencer

Published: August 18, 2016

The following is a notification from Intertek that the identified below Test Report contains falsified test data of unknown origin.

Product Description	<i>In-Line Silencer Model MVA 2224-180</i>
Manufacturer	<i>Innovative Metal Industries</i>
Identification	<i>Test Report 10144805CRT-00, associated to Order No. 101144805, dated May 15, 2013, 5 pages in length, with first falsified data table as shown below</i>
What to do	<i>Immediately stop using any product procured based on the falsified report and report the incident to Intertek at product.incidents@intertek.com. If in doubt, contact Intertek for report validation.</i>

Report Images: Falsified Test Report Cover Page and Sample of Falsified Data from Page 3



Octave Band Center Frequency (Hz)	Insertion Loss				
	0 Flow	Flow 1	Flow 2	Flow 3	Flow 4
63	14	14	14	14	14
125	24	24	24	24	24
250	27	27	28	28	28
500	36	36	36	37	37
1000	44	44	44	44	43
2000	55	55	55	55	54
4000	42	42	42	42	41
8000	41	41	41	41	41