



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published:
Revised:

4-Oct-22

Public Notice ID: 2022-21
Page 1 of 2

Safety Concern with Intertek Certified Product

2-in-1 Photoelectric Smoke & Fire + Carbon Monoxide Alarms

Notification Type:	Safety / Sécurité
Certification Type:	ETL Listed - US

Notification

Intertek notifies consumers, retailers and distributors of a potential safety concern involving the Intertek Certified products identified below.

Company Identification

Universal Security Instruments Inc

Product Identification

Front of recalled hardwired USI Electric 2-in-1 Photoelectric Smoke & Fire + Carbon Monoxide alarm Model MPC122S with a manufacturing date code of 2017JUN0. This ETLus . Recall number: 22-111 can be found at CPSC LINK: <https://www.cpsc.gov/Recalls/2022/Universal-Security-Instruments-Recalls-Combination-Photoelectric-Smoke-Carbon-Monoxide-Alarms-Due-to-Risk-of-Failure-to-Alert-Consumers-to-Hazardous-Levels-of-Carbon-Monoxide>

Hazard Involved

The alarms can fail to alert consumers to the presence of a hazardous level of carbon monoxide, posing a risk of carbon monoxide poisoning or death. Carbon monoxide (CO) is an odorless, colorless, poisonous gas.

What To Do

Use of these products should be immediately discontinued and return to the Applicant for replacement or repair. Distributors and retailers should discontinue sales and return inventories to their suppliers.